

Government of the People's Republic of Bangladesh
Chemical Laboratory
Custom House, Chattogram.
Web: www.chc.gov.bd/reports
E-mail: chcchemi.laboratory@gmail.com

Scanned
04 JUL 2022

Subject: Chemical Test Report.

Sample Received On: 03.07.2022


Sample Code No:

Date of Delivery:

Test Report No:

1237

01	B/E No. & Date	:	C-1166126, Date-30.06.2022.
	File No. & Date	:	
02	Name of Section	:	Section-7(A)
03	Declared Commodity Name as per Invoice/BE	:	Invoice Item Refrigerant Gas R410a (Sample:01 Cylinder)
04	Method of Test/Analysis	:	Phy.tests C/ARI test etc.
05	Physical & Chemical Properties & Ingredients Found	:	Colourless, Liquified gas in cylinder, Nearly odourless, Insoluble in water, Sp.gr.<1 at ambient temperature, p ^H =7 C/ARI test =+Ve. Ingredients: Difluoromethane, Pentafluoroethane.
06	Result of Physical /Chemical Test/Analysis	:	The supplied sample is "Mixture of Difluoromethane & Pentafluoroethane." It is also known as "R410a."
07	Probable use of Imported Goods.	:	It is used as "Refrigerant" in various purposes.
08	Comments (If any)	a	It does not deplete the ozone layer.
		b	
		c	


04/09/22

Signature of Examiner
Md. Helal Hassan
Chemical Assistant
Custom House, Chattogram.

04-04-22 11:33 AM

- The results described here are based only on the supplied sample(s) in this laboratory.
- Complain or query regarding test report(s) should be lodged within one month of report delivery date.
- The laboratory is not responsible for the data quality affected due to sampling, transporting and storage conditions of the sample(s) maintained before received in the laboratory.
- This report or any part of this should not be published without prior approval of the authority.