

Government of the People's Republic of Bangladesh  
Chemical Laboratory  
Custom House, Chattogram.  
Web: [www.chc.gov.bd/reports](http://www.chc.gov.bd/reports)  
E-mail: [chcchemi.laboratory@gmail.com](mailto:chcchemi.laboratory@gmail.com)

Scanned  
12 SEP 2022

**Subject: Chemical Test Report.**

Sample Received On: 11.09.2022


Sample Code No:

Date of Delivery:

Test Report No:

1682

01	<b>B/E No. &amp; Date</b>	:	C-1549050, Date-08.09.2022.
	<b>File No. &amp; Date</b>	:	
02	<b>Name of Section</b>	:	Section-2
03	<b>Declared Commodity Name as per Invoice/BE</b>	:	Invoice Item BNF-R22 (Refrigerant Gas) (Sample:01 Cylinder)
04	<b>Method of Test/Analysis</b>	:	Phy.tests C/ARI test etc.
05	<b>Physical &amp; Chemical Properties &amp; Ingredients Found</b>	:	Colourless. Liquified gas in disposable cylinder. MF=CHClF <sub>2</sub> C/ARI test =+Ve.
06	<b>Result of Physical /Chemical Test/Analysis</b>	:	The supplied sample is "Chlorodifluoromethane." It is also known as R-22.
07	<b>Probable use of Imported Goods.</b>	:	It is used as "Refrigerant" in various purposes.
08	<b>Comments (If any)</b>	a	It depletes the ozone layer.
		b	
		c	

  
22/09/22

Signature of Examiner  
Md. Helal Hassan  
Chemical Assistant  
Custom House, Chattogram.

12-Sep-22 2:39 PM

- Notes:
- The results described here are based only on the supplied sample(s) in this laboratory.
  - Complain or query regarding test report(s) should be lodged within one month of report delivery date.
  - The laboratory is not responsible for the data quality affected due to sampling, transporting and storage conditions of the sample(s) maintained before received in the laboratory.
  - This report or any part of this should not be published without prior approval of the authority.