

Government of the People's Republic of Bangladesh
Chemical Laboratory
Custom House, Chattogram.
Web: www.chc.gov.bd/reports
E-mail: chcchemi.laboratory@gmail.com

Scanned
06 NOV 2022

Subject: **Chemical Test Report.**


Sample Received On: 31.10.2022

Sample Tag No: 594438

Date of Delivery:

Test Report No: 2103

01	B/E No. & Date	:	C-1756201, Date-23.10.2022.
	File No. & Date	:	
02	Name of Section	:	Section-7(A)
03	Declared Commodity Name as per Invoice/BE	:	Invoice Item ABC Dry Powder
04	Method of Test/Analysis	:	Phy. tests C/PFE test etc.
05	Physical & Chemical Properties & Ingredients Found	:	Powder form. Yellowish colour. Mild odour. Very slightly soluble in water and alcohol. Sp.gr.>1 NH_4^+ , SiO_2 , PO_4^{3-} , SO_4^{2-} , Mica, Bentonite etc. test=+Ve. Ingredients: Ammonium Dihydrogen Phosphate, Silicon Dioxide, Mica, Ammonium Sulphate.
06	Result of Physical /Chemical Test/Analysis	:	The supplied sample is " Preparation for Fire Extinguisher. "
07	Probable use of Imported Goods.	:	It is used in fire extinguishing purposes.
08	Comments (If any)	a	
		b	
		c	


06/11/22

Signature of Examiner
Md. Helal Hassan
Chemical Assistant
Custom House, Chattogram.

05-Nov-22 3:53 PM

- Notes:
- The results described here are based only on the supplied sample(s) in this laboratory.
 - Complain or query regarding test report(s) should be lodged within one month of report delivery date.
 - The laboratory is not responsible for the data quality affected due to sampling, transporting and storage conditions of the sample(s) maintained before received in the laboratory.
 - This report or any part of this should not be published without prior approval of the authority.